

## County of Orange, Health Care Agency Environmental Health Division

Mail: PO Box 25400, Santa Ana, CA 92799

Office: 1241 E. Dyer Rd., Ste. 120, Santa Ana, CA 92705

Phone: (714) 433-6286 / Fax: (714) 433-6481

OCBackflowTests@ochca.com

## BACKFLOW PREVENTION ASSEMBLY TEST & MAINTENANCE REPORT

OWNER:		ADDRESS:		
		MODEL:	SIZE:	TYPE:
SERIAL N	UMBER:	LOCATION:		
	REDUCED PRESSURE I		7	LINE PRESSURE
	DOUBLE CHECK VALVE	ASSEMBLY		
	CHECK VALVE #1	CHECK VALVE #2	RELIEF VALVE	PVB / SVB
INITIAL TEST	CLOSED TIGHT	HELD AT PSID CLOSED TIGHT FAILED LEAKED	OPENED AT PSID DID NOT OPEN	AIR INLET  OPENED AT PSID  Y N  OPENED FULLY □ □
	□ CLEANED	☐ CLEANED	□ CLEANED	CHECK VALVE
R E P A I R S	□ REPLACED	□ REPLACED	□ REPLACED	HELD AT PSID CLOSED TIGHT
FINAL TEST	HELD ATPSID CLOSED TIGHT	HELD AT PSID CLOSED TIGHT	OPENED AT PSID	AIR INLETPSID CHECK VALVEPSID CLOSED TIGHT □
PASS   FAIL		PURVEYOR_		
	TEST (SIGNATURE)			STER NO. DATE
FINAL TEST (SIGNATURE) PRINT NA		PRINT NAME	CERT. TESTER NO. DATE	
TESTER'S COMPANY NAME			TESTER'S PHONE NUMBER	